

RIWAL CERAMICHE S.P.A.

Date: 01/07/2010

**DIN 51130 - DETERMINATION OF ANTI-SLIP
PROPERTIES**

For the samples marked: DOCKS 30x60
ALFALUX

Surface characteristic:

Smooth

Structured

Total average value	Group classification
from 6° to 10°	R9
from 10° to 19°	R10
from 19 to 27°	R11
from 27° to 35°	R12
over 35°	R13

RESULTS:

Average total acceptance angle:

6°

CLASSIFICATION:

Group of ANTI-SLIP properties:

R9

FIRMA : Davide Gilli